



Product Service

Attestation of Conformity

No. N8A 005429 0013 Rev. 00

Holder of Certificate: **Zhejiang Zhongguang Electrical Co., Ltd**
No.96 Yunjing Road Shuige Industry Area
323000 Lishui City, Zhejiang
PEOPLE'S REPUBLIC OF CHINA

Product: **Heat pumps**
Split heat pump

Model(s): **1) AHb14D, 2) AHb16D, 3) AHb18D**

Parameters:


Rated voltage:	220-240V~
Rated frequency:	50Hz
Rated input power:	1) 6000W, 2) 6900W, 3) 7400W
Rated current:	1) 28A, 2) 32A, 3) 34A
Protection class:	I
Degree of protection:	Ordinary
Refrigerant:	R410A

Tested according to: EN 60335-2-40:2003/A13:2012
EN 60335-1:2012/A15:2021
EN 62233:2008

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.: 704012162510-00

Date, 2022-03-14


(Bin Chen)